

ist Hersteller und verantwortlich für:

Konformitätserklärung / Declaration of Conformity

Produkt-Typ:	Plug & Play Photovoltaik-Set für Netzparallelbetrieb steckbar mittels Haushaltsstecker in Endstromkreis
Modell:	1800 - 1920 Wp Plug & Play (CN), 4 Panels / Solarflow 800 Pro
Komponenten:	4x JA Solar JAM54D41-450/LB / 450 Wp / IP-67 / Schutzklasse II 1x Zendure Solarflow 800 Pro, Max. DC 2640, VDC 15-55V, Max. AC 600W (Firmware per Standort-Erkennung / Netzprofil CH_NA EEA-NE7—CH2020 gedrosselt) 1x Anschlusskabel vorkonfektioniert mit Betteri Buchse BC01 IP67, 3moder 20m / 3x1,0mm2 Leitung / AC Seitig CH-Typ 13 Stecker IP 55

Konform nach ESTI-Mitteilung 07/2014 und in Übereinstimmung mit der Verordnung über elektrische Niederspannungserzeugnisse (NEV; SR 734.26) (Stand 14.08.2024).

Dazu angewandte Normen:

JA Solar JAM54D41-450/LB - Bifacial-Doppelglas	N 61215-1:2016, EN 61215-1-1:2016, IEC 61215-2:2016, EN 61215-2:2017, IEC 61730-1:2016, EN IEC 61730-1:2018, EN IEC 61730-1:2018/AC:2018-06, IEC 61730-2:2016, EN IEC 61730-2:2018, EN IEC 61730-2:2018/AC:2018-06
Zendure Solarflow 800 Pro	2014/53/EU (RED), 2011/65/EU (RoHS), 2015/863/EU (RoHS), EN 62109-1:2010, EN 62109-2:2011, ETSI EN 301 489-1 V2.2.3 (2019-11), ETSI EN 301 489-3 V2.1.1 (2019-03), ETSI EN 301 489-17 V3.2.4 (2020-09), EN 55032:2015+A11:2020, EN 55035:2017+A11:2020, ETSI EN 300 328 V2.2.2 (2019-07), ETSI EN 300 440 V2.2.1 (2018-07), IEC 62321-3-1:2013, IEC 62321-4:2013+AMD1:2017, IEC 62321-5:2013, IEC 62321-6:2015, IEC 62321-7-1:2015, IEC 62321-7-2:2017, IEC 62321-8:2017
Zendure BC01 Anschlusskabel vorkonfektioniert in 3m	Betteri Buchse Wechselrichterseite, Schutzart IEC EN 60529 IP67, Anschlusskabel 5m oder 10m H07RN-F, EN 50525-2-21: 2011, Stecker CH Typ 13: IEC 60884-1 (Ed 4.0): 2022 / SN 441011-1: 2019 +Corr2019 / SN 441011-2-1:2021, IP55
ROHS Konformität	Gesamtes Set konform gemäss IEC EN 63000: 2018

Michael Sebel, Geschäftsführung erneuer.bar services GmbH

M. Salf



Shanghai JA Solar Technology Co., Ltd. No. 118, Lane 3111, West Huancheng road Feng Xian District Shanghai 201401, P. R. China Tel: +86 (21) 3718 1000

CE Declaration of Conformity

Directive 2014/30/EU (Electromagnetic Compatibility)



Issuer's name and address:

Shanghai JA Solar Technology Co. Ltd No 118, Lane 3111, West Huancheng road, Feng Xian District, Shanghai 201401, P.R. CHINA Tel: +86 21 3718 1000

Product: Crystalline silicon photovoltaic modules

Type designation:

JAM60S10-XXX/MR, JAM72S10-XXX/MR, JAM60S17-XXX/MR, JAM72S17-XXX/MR, JAM78S10-XXX/MR

JAM60D10-XXX/MB, JAM72D10-XXX/MB, JAM78D10-XXX/MB

JAM60S20-XXX/MR, JAM60S21-XXX/MR, JAM66S20-XXX/MR, JAM72S20-XXX/MR

JAM60D20-XXX/MB, JAM72D20-XXX/MB

JAM54S30-XXX/MR, JAM54S31-XXX/MR, JAM66S30-XXX/MR, JAM72S30-XXX/MR, JAM78S30-XXX/MR

JAM54D30-XXX/MB, JAM54D31-XXX/MB, JAM66D30-XXX/MB, JAM72D30-XXX/MB, JAM78D30-XXX/MB

JAM54S30-XXX/GR, JAM54D31-XXX/GB, JAM66S30-XXX/GR, JAM72S30-XXX/GR, JAM78D30-XXX/GR

JAM54D30-XXX/GB, JAM54D31-XXX/GB, JAM66D30-XXX/GB, JAM72D30-XXX/GB, JAM78D30-XXX/GB

JAM54D40-XXX/GB, JAM54D41-XXX/GB, JAM66D40-XXX/GB, JAM72D40-XXX/MB, JAM78D40-XXX/MB

JAM54D40-XXX/MB, JAM54D41-XXX/MB, JAM66D40-XXX/MB, JAM72D40-XXX/MB, JAM78D40-XXX/MB

JAM54S40-XXX/GR, JAM54S41XXX/GR, JAM66S40-XXX/GR, JAM72S40-XXX/GR, JAM78S40-XXX/MR

JAM54S30-XXX/LR, JAM54S31-XXX/LR, JAM66S40-XXX/MR, JAM72S30-XXX/LR, JAM78S40-XXX/LR, JAM78S40-XXX/LR

JAM54D30-XXX/LB, JAM54D40-XXX/LB, JAM54D41-XXX/LB, JAM72D30-XXX/LB, JAM78D30-XXX/LB, JAM66D45-XXX/LB, JAM72D40-XXX/LB, JAM72D40-XXX/LB, JAM78D40-XXX/LB, JAM66D45-XXX/LB, JAM72D40-XXX/LB, JAM72D40-XXX/LB, JAM78D40-XXX/LB, JAM78D40-XXX/LB

The designated product is in conformity with the European Directive: 2014/30/EU Council Directive on the harmonization of the laws of the Member States relating to electrical equipment designed for use within certain voltage limits.

The technical documentation and full compliance with the standards listed below proved the conformity of the product with the requirements of the above-mentioned EC Directive:

EN 61000-6-2:2005

EN 61000-6-3:2007+A1:2011

The institute Intertek Testing Services Shanghai, Building No.86, 1198 Qinzhou Road (North), Shanghai 200233(China) has tested and certified the product.

Certificate Nov. 230501326SHA-V1

We hereby declare this Declaration of Conformity is issued under the sole responsibility of Shanghai JA Solar Technology Co. Ltd

Shanghai,

Shanghai JA Solar Technology Co., Ltd.

August 11th, 2023



Shanghai JA Solar Technology Co., Ltd. No. 118, Lane 3111, West Huancheng road Feng Xian District Shanghai 201401, P. R. China Tel: +86 (21) 3718 1000

CE Declaration of Conformity

Directive 2014/35/EU (Low Voltage)



Issuer's name and address:

Shanghai JA Solar Technology Co. Ltd No 118, Lane 3111, West Huancheng road, Feng Xian District, Shanghai 201401, P.R. CHINA Tel: +86 21 3718 1000

Product: Crystalline silicon photovoltaic modules

Type designation:

JAM60S10-XXX/MR, JAM72S10-XXX/MR, JAM60S17-XXX/MR, JAM72S17-XXX/MR, JAM78S10-XXX/MR JAM60D10-XXX/MB, JAM72D10-XXX/MB, JAM78D10-XXX/MB JAM60S20-XXX/MR, JAM60S21-XXX/MR, JAM66S20-XXX/MR, JAM72S20-XXX/MR JAM60D20-XXX/MB, JAM72D20-XXX/MB JAM54S30-XXX/MR, JAM54S31-XXX/MR, JAM66S30-XXX/MR, JAM72S30-XXX/MR, JAM78S30-XXX/MR JAM54D30-XXX/MB, JAM54D31-XXX/MB, JAM66D30-XXX/MB, JAM72D30-XXX/MB, JAM78D30-XXX/MB JAM54S30-XXX/GR, JAM54S31-XXX/GR, JAM66S30-XXX/GR, JAM72S30-XXX/GR, JAM78S30-XXX/GR JAM54D30-XXX/GB, JAM54D31-XXX/GB, JAM66D30-XXX/GB, JAM72D30-XXX/GB, JAM78D30-XXX/GB JAM54D40-XXX/GB, JAM54D41-XXX/GB, JAM66D40-XXX/GB, JAM72D40-XXX/GB, JAM78D40-XXX/GB JAM54D40-XXX/MB, JAM54D41-XXX/MB, JAM66D40-XXX/MB, JAM72D40-XXX/MB, JAM78D40-XXX/MB JAM54S40-XXX/GR, JAM54S41XXX/GR, JAM66S40-XXX/GR, JAM72S40-XXX/GR, JAM78S40-XXX/GR JAM54S40-XXX/MR, JAM54S41XXX/MR, JAM66S40-XXX/MR, JAM72S40-XXX/MR, JAM78S40-XXX/MR JAM54S30-XXX/LR, JAM54S31-XXX/LR, JAM72S30-XXX/LR, JAM78S30-XXX/LR, JAM72S40-XXX/LR, JAM78S40-XXX/LR JAM54D30-XXX/LB, JAM54D40-XXX/LB, JAM54D41-XXX/LB, JAM72D30-XXX/LB, JAM78D30-XXX/LB, JAM66D45-XXX/LB, JAM72D40-XXX/LB, JAM72D42-XXX/LB, JAM78D40-XXX/LB

The designated product is in conformity with the European Directive: 2014/30/EU Council Directive on the harmonization of the laws of the Member States relating to electrical equipment designed for use within certain voltage limits.

The technical documentation and full compliance with the standards listed below proved the conformity of the product with the requirements of the above-mentioned EC Directive:

EN IEC 61730-1:2018

EN IEC 61730-1:2018/AC :2018-06

EN IEC 61730-2:2018

EN IEC 61730-2:2018/AC:2018-06

The institute TUV SUD Product Service GmbH, Ridlerstrasse 65, 80339 Munich (Germany) has tested and certified the product.

Certificate No.: N8A072092 0296

We hereby declare this peclaration of Conformity is issued under the sole responsibility of Shanghai JA Solar Technology Co. Ltd

Shanghai, Shanghai JA Solar Technology Co., Lt

August 11th, 2023

JA SOLAR

Harvest the Sunshine

510W @ @ @







JAM60D41 LB Black Module n-type Double Glass Bifacial Modules

Premium Cells

Bycium+ **16BB**

26%



MBB Half-Cell Technology


Cell Conversion Efficiency

Premium Modules

Higher power generation better LCOE n-type with very Lower LID

Better Temperature Coefficient

Setter low irradiance response




15-year product warranty

30-year linear power output warranty

Comprehensive Certificates

- IEC 61215, IEC 61730, UL 61215, UL 61730
- ISO 9001: 2015 Quality management systems
- ISO 14001: 2015 Environmental management systems
- ISO 45001: 2018 Occupational health and safety management systems
- IEC 62941: 2019 Terrestrial photovoltaic (PV) modules Quality system for PV module manufacturing


















MECHANICAL PARAMETERS

Cell	Mono
Weight	27.3kg
Dimensions	1953±2mm×1134±2mm×30±1mm
Cable Cross Section Size	4mm²(IEC), 12 AWG(UL)
No. of cells	120(6×20)
Junction Box	IP68, 3diodes
Connector	QC 4.10-351/ MC4-EVO2A
Cable Length (Including Connector)	Portrait: 300mm(+) /400mm(-) Landscape: 1200mm(+)/1200mm(-)
Front Glass/Back Glass	2.0mm/2.0mm
Packaging Configuration	36pcs/Pallet, 864pcs/40HQ Container

Remark: customized frame color and cable length available upon request

ELECTRICAL PARAMETERS AT STC

	JAM60D41		JAM60D41		JAM60D41	JAM60D41
TYPE	-485/LB	-490/LB	-495/LB	-500/LB	-505/LB	-510/LB
Rated Maximum Power(Pmax) [W] 485	490	495	500	505	510
Open Circuit Voltage (Voc) [V]	43.25	43.45	43.65	43.85	44.05	44.25
Maximum Power Voltage(Vmp) [V	36.28	36.49	36.70	36.91	37.11	37.31
Short Circuit Current(Isc) [A]	14.24	14.30	14.36	14.42	14.48	14.54
Maximum Power Current(Imp) [A]	13.37	13.43	13.49	13.55	13.61	13.67
Module Efficiency [%]	21.9	22.1	22.4	22.6	22.8	23.0
Power Tolerance			0~+3%			
Temperature Coefficient of Isc(α _	c) +0.045%/°C					
Temperature Coefficient of Voc (β	-0.250%/°C					
Temperature Coefficient of Pmax	-0.290%/°C					
STC		Irradiance 1000W/m², cell temperature 25°C, AM1.5G				5G


Remark: Electrical data in this catalog do not refer to a single module and they are not part of the offer.

They only serve for comparison among different module types.

ELECTRICAL CHARACTERISTICS WITH 10% SOLAR IRRADIATION RATIO

TYPE	JAM60D41 -485/LB	JAM60D41 -490/LB	JAM60D41 -495/LB	JAM60D41 -500/LB	JAM60D41 -505/LB	JAM60D41 -510/LB
Rated Max Power(Pmax) [W]	524	529	535	540	545	551
Open Circuit Voltage(Voc) [V]	43.25	43.45	43.65	43.85	44.05	44.25
Max Power Voltage(Vmp) [V]	36.28	36.49	36.70	36.91	37.11	37.31
Short Circuit Current(Isc) [A]	15.38	15.44	15.51	15.57	15.64	15.70
Max Power Current(Imp) [A]	14.44	14.50	14.57	14.63	14.70	14.76
Irradiation Ratio (rear/front)			10%			

CHARACTERISTICS



OPERATING CONDITIONS

Maximum System Voltage	1500V DC
Operating Temperature	-40°C~+85°C
Maximum Series Fuse Rating	30A
Maximum Static Load, Front	5400Pa(112 lb/ft²)
Maximum Static Load, Back	2400Pa(50 lb/ft²)
NOCT	45±2°C
Bifaciality	80%±10%
Safety Class	Class II
Fire Performance	UL Type 29/Class C



Headquarters

No. 8 Building, Nuode Center, No.1 Courtyard, East Auto Museum Road, Fengtai District, Beijing

Tel: +86 10 6361 1888 Fax: +86 10 6361 1999

E-mail: sales@jasolar.com marketing@jasolar.com www.jasolar.com

Specifications subject to technical changes and tests. JA Solar reserves the right of final interpretation.

Version No.: Global-EN-20241118A



Shanghai JA Solar PV Technology Co., Ltd. No. 36, Jiang Chang San Rd Zhabei, Shanghai 200436 P. R. China

Tel: +86 (21) 6095 5531 Fax: +86 (21) 6095 5959

Declaration of antireflection glass

JA Solar as the PV module manufacturer hereby declares that all the JA Solar modules recently manufactured (starting from 2014) have on the front side a tempered and high-transmission glass covered by anti-reflection coating to reduce light reflection and hence absorb more solar energy and generate more electric current.

All JA Solar customers are encouraged to consult with JA Solar technical support staff with any further question they may have.

Yours faithfully,

Shanghai JA Solar PV Technology Co., Ltd. Global Customer Service Department March 18th, 2020



Certificate of Conformity

Certificate Number: CN-PVES-250223

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant: Zendure USA Inc.

1765 E BAYSHORE RD # 201 EAST PALO ALTO, CA 94303-5501 USA

Product: SolarFlow 800 Pro Power Station SolarFlow 800 AC+ Power Station

Ratings & Principle See appendix of Certificate of Conformity

Characteristics:

Model: ZDSF800P, ZDSF800AC

Brand Name<s>: ZENDURE SuperCharged+-

Product Complies with: NA/EEA-NE7:2020, Grid connection for power generation systems to the

low-voltage grid

Type approval for Type A2

Certificate Issuing Office

Name & Address:

Intertek Testing Services Ltd. Shanghai

West Area, 2nd Floor, No. 707, Zhangyang Road

China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China

Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012

Test Report No.<s>: 250103067GZU-002, 20 May 2025

Additional information in Appendix.

Signature

Certification Manager: Grady Ye

busta

Date: 27 May 2025

ACCREDIA T

PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250223

Model	ZDSF800P	ZDSF800AC			
PV Input					
Max. input Voltage	55 Vdc				
MPPT voltage Range	14 -55 Vdc				
Max. input current	4*18 Adc				
PV Isc	4*22.5 Adc				
AC Side					
Nominal input/output voltage	Nominal input/output voltage 230 Vac				
Nominal input/output Frequency	50	Hz			
Max. output current (on-grid)	3.5	Aac			
Max. output power(on-grid)	800) W			
Max. output current (off-grid)	4.35	Aac			
Max. output power(off-grid)	100	0 VA			
Max. input current	4.35	Aac			
Max. input power	1000 W				
Power factor range	0.8leading~0.8lagging				
Battery Side					
Battery Type	LiFe	ePO			
Battery Rated Energy	1920 Wh				
Battery Rated Voltage	48 V dc				
Charge/Discharge Voltage Range	37.5~54.75 Vdc				
Max. Charge/Discharge Power (Without					
Extra Battery)	a Battery)				
Max. Charge/Discharge Current (Without Extra Battery)	30 Adc				
Max. Charge/Discharge Power (With Extra Battery)	2000 W				
Max. Charge/Discharge Current (With Extra Battery)	40 Adc				
General information					
Safety level	Class I				
Ingress Protection	IP 65				
Operation Ambient Temperature	-20°C -	-20℃ - +55℃			
Software version	V1				
1					

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.